

VEOLIA WATER SAMPLING
SEPTEMBER 30, 2005
DETECTIONS ABOVE THE MCL

POE	Actual Sample Location	TTHMs Detections 80.0 ug/L MCL	HaloAcetic Acids Detections 60.0 ug/L MCL
4	Pizza Hut @ 86th & Keystone (Keystone At The Crossing)	98.1	102.4
4	Extended Stay America @ 9750 Lakeshore Drive		87
4	Shell Gas Station @ 96th & Allisonville		92.4
4	White River North Treatment Plant		82.5
4	McDonalds @ 8907 E. 116th	83.4	96.6
1	7430 Rockville Rd.	90.7	104.6
1	4141 S. Madison	100.1	
1	Firestation @ Ohio & West St.	90.6	103
3	Firestation @ 7002 N. Lafayette Rd.	90.6	
3	Speedway Gas Station @ 6315 W. 56th St.	86.2	
3	McDonalds @ 6830 W. 38th St.	87.4	